

east cape engineering, inc.

44 Route 28
P.O. Box 1525
Orleans, MA 02653

508-255-7120 PHONE
508-255-3176 FAX

WEB SITE: www.eastcapeengineering.com

CIVIL ENGINEERING
WATER RESOURCES
ENVIRONMENTAL
SANITARY
STRUCTURAL
WATERFRONT

LAND SURVEYING
LAND COURT
SITE PLANNING
CERTIFIED PLANS

May 25, 2016

Mr. Mark Dakers
Division of Solid Waste
MaDEP/SERO
20 Riverside Drive
Lakeville, MA 02347

RE: Truro Municipal Landfill, Submission of Field Data and Laboratory Analysis

Dear Mr. Dakers,


Enclosed please find a copy of the Laboratory Analysis Report for groundwater samples obtained on May 16, 2016 from the existing monitoring well sites at the Truro Landfill. Also enclosed are Groundwater Field Analysis Forms, which indicate the groundwater parameters analyzed in the field, for each well, at the time each sample was taken. The results of field analysis performed on May 16, 2016 at each well are shown in red. The groundwater sampling events occur at the Truro Landfill on a semi-annual basis, with the next sampling event scheduled to occur in October or November of 2016.

Please note that this is the first sampling event to include analysis for Calcium and 1,4 Dioxane. One of the wells, T1-4D, (deep well closest to cap) was positive for 1,4 Dioxane with a result of 1440 ng/l. Upon receipt the Laboratory Analysis Report on May 24, 2016, I left a voicemail message with Mr. Douglas Coppi at the DEP as notification of the positive result. I asked for guidance on any further required action. There are no known private wells within 500ft. of this monitoring well, nor does the monitoring well lie within a PWS Zone 1. All other groundwater monitoring wells at the site had non-detects for 1,4 Dioxane.

Quarterly Gas Probe Sampling was also conducted at the four gas probe locations, and within the swap shop building. These results are shown in the attached Gas Probe Sampling Data Forms, with the data for first two quarters of 2016 shown in red.

If you have any questions, please feel free to call this office at 508-255-7120.

Sincerely,



Christopher S. Wickson