

Memo

To: Jeffery Ribeiro, Town Planner

From: Jarrod J. Cabral, DPW Director

Date: December 12, 2019

Re: Cloverleaf

After review of the proposed Cloverleaf site plan for the property located at 22 Highland Road, it has been determined that the proposed plan changes to the curb cut depicts adequate drainage throughout the site.

The drainage as proposed will contain storm water run-off on site and meets the minimum regulatory standard. The property is situated well within the DOT roadway layout, the access as proposed will not result in a negative impact to Town or DOT infrastructure.

The DPW has received comments back from DOT, and the Provincetown Water Department regarding our utility permit. We currently have no significant changes of note other than adding fire hydrants within the cloverleaf as recommended by Chief Collins.

The Cloverleaf layout as proposed provides enough open storage space for snow removal. Snow removal amounts will not result in delayed access to fire hydrants or block catch basins.

Sincerely,
Jarrod J. Cabral
Director
Department of Public Works
Truro Ma 02666